


	VDC	vatrodojavna centrala
	11/11	kombinirani javljač požara(optički)
	11/11	kombinirani javljač požara(optički) u podnožju IP 65
	11/12	kombinirani javljač požara(temperturni)
	11/11	kombinirani javljač požara s paralelnim indikatorom(optički)
	11/11	ručni javljač požara
S1.1 		alarmna truba
S2.1 		alarmna truba s bljeskalicom
	1/11	alarmna sirena u podnožju javljača
	BXAIM 2.33	modul za spoj klasičnih javljača na adresibilnu petlju
	RO 2.11	ulazno izlazni modul(1 izlaz ; 2 ulaza)
	PPZ 2.14	ulazni modul(4 ulaza)
	R-KOT 1/14	izlazni modul(2 izlaza, 4 ulaza)
	OD-1	centrala za odimljavanje


MLADEN TOMIĆ
 mag.ing.el.
 E2425
 OVLAŠTENI INŽENJER
 ELEKTROTEHNIKE

INVESTITOR : MIRJAM j.d.o.o.		SADRŽAJ : VATRODOJAVA - LEGENDA				
GRAĐEVINA : HOTEL **** "MIRJAM"		PROJEKTANT : MLADEN TOMIĆ, dipl.ing.el.				
LOKACIJA : k.č.z. 831/10, K.O. VELIKO BRDO	d.o.o. za projektiranje, nadzor i izvođenje električnih instalacija, Kalalarga 16, Makarska MB: 060014265, OIB: 41489075623 Tel: 021/613-425, e-mail: in-loco@stl-com.hr	MJERILO :	ZOP :	BROJ PROJEKTA :	DATUM :	BR. NACRTA:
PROJEKT : ELEKTROTEHNIČKE INSTALACIJE		-	AH-LL-01/14	TD-E-17/50	07.2017.g.	4.33