


- ===== LED traka 7.2W/m u Al profilu, IP65, 3m
- ===== LED traka 7.2W/m u Al profilu, IP65, 1.5m
- LED traka 7.2W/m u Al profilu, IP20

-  Panik svjetiljka ugradna Sirios LED 8W, 3h, pripravní spoj
-  Panik ugradna Sirios LED 8W, 3h, s piktogramom ravno, trajni spoj
-  Panik ugradna Sirios LED 8W, 3h, s piktog. ravno dvostrano, trajni spoj
-  Panik ugradna Sirios LED 8W, 3h, s piktogramom lijevo-desno, trajni spoj
-  Panik nadgradna zidna Sirios LED 8W, 3h, s piktog. ravno, trajni spoj, IP65
-  Panik svjetiljka nadgradna zidna Sirios LED 8W, 3h, pripravní spoj, IP65
-  Panik svjetiljka nadgradna Sirios LED 8W, 3h, pripravní spoj
-  Panik svjetiljka nadgradna Sirios LED 8W, 3h s piktogramom ravno
-  Panik svjetiljka nadgradna Sirios LED 8W, 3h s piktogramom dvostrano

 **NIKO KRAMPUS**
dipl.ing.el.
E 659 OVLASTENI INŽENJER
ELEKTROTEHNIKE

NIKO DUBROVNIK d.o.o. DUBROVNIK		Građevina:	HOTEL OSMINE - REKONSTRUKCIJA DOGRADNJA I NADOGRADNJA		
		Investitor:	HOTEL OSMINE d.o.o.		
Glavni projektant:	Antun Poković dipl.ing.arh.	Projekt:	Glavni elektrotehnički projekt	Broj revizije	
Projektant:	Niko Krampus, dipl.ing.el. 	Sadržaj:	Legenda oznaka	Broj revizije	
Suradnik:	Pero Sjekavica, dipl.ing.	travanj, 2016.	Stranica: 9/9	T.D. 98-1/15	Nacrt br: E1