

LEGENDA OZNAKA:



OPTIČKI ANALOGNO ADRESABILNI JAVLJAČ POŽARA HOCHIKI ALG-EN U SPUŠTENOM STROPU S PARALELNIM INDIKATOROM



OPTIČKI ANALOGNO ADRESABILNI JAVLJAČ POŽARA HOCHIKI ALG-EN



TERMODIFERENCIJALNI ADRESABILNI JAVLJAČ POŽARA HOCHIKI ACB-E U SPUŠTENOM STROPU S PARALELNIM INDIKATOROM



TERMODIFERENCIJALNI ADRESABILNI JAVLJAČ POŽARA HOCHIKI ACB-E



MULTIFUNKCIJSKI OPTIČKI+TERMIČKI ANALOGNO ADRESABILNI JAVLJAČ POŽARA HOCHIKI ACA-E



RUČNI ADRESABILNI JAVLJAČ POŽARA HOCHIKI SCP-E S UGRAĐENIM IZOLATOROM PETLJE



RUČNI ADRESABILNI JAVLJAČ POŽARA HOCHIKI U IP ZAŠTITI



IZOLATOR PETLJE HOCHIKI YBO-R/SCI



ADRESABILNA SIRENA ZA MONTAŽU NA JAVLJAČ YBO-BSB



VANJSKA SIRENA S BLJESKALICOM (CRVENE BOJE)



VANJSKA SIRENA U VODOTJESNOJ ZAŠTITI WS2 (NAPAJANJE IZ PETLJE)



ADRESABILNI IZLAZNI MODUL (1 izlaz 230VAC) HOCHIKI CHQ-MRC



ADRESABILNI ULAZNI MODUL (2 ulaza) HOCHIKI CHQ-DIM



VATRODOJAVNA CENTRALA SA AKU BATERIJAMA



PARALELNI TABLO



PROTUPOŽARNA MOTORNA ZAKLOPKA S OZNAKOM



VATRODOJAVNI KABEL JB-Y(Sf)Y 2x2x0.8 qmm



VATRODOJAVNI KABEL JB-Y(Sf)Y 4x2x0.8 qmm za međuvezu VDC i Paralelni Tablo

L1.55

OZNAKA ELEMENTA VD sustava; L-loop/petlja; 1-broj petlje (1-4); 55-redni broj elementa VDC sustava



USPONSKA VERTIKALA ZA KABELSKJE VODOVE SVIH ELEMENATA SUSTAVA ZA DOJAVU POŽARA



AUTOMATIKA ZA PP VRATA



IC BARIJERA (transmitter-aktivni dio)



IC BARIJERA (receiver-pasivni dio)

NIKO KRAMPUS
dipl.ing.el.
E 659 OVLASTENI INŽENJER
ELEKTROTEHNIKE

NIKO DUBROVNIK d.o.o. DUBROVNIK		Građevina:	HOTEL OSMINE - REKONSTRUKCIJA DOGRADNJA I NADOGRADNJA		
		Investitor:	HOTEL OSMINE d.o.o.		
Glavni projektant:	Antun Poković dipl.ing.arh.	Projekt:	Glavni elektrotehnički projekt	Broj revizije	
Projektant:	Niko Krampus, dipl.ing.el.	Sadržaj:	Legenda oznaka	Broj revizije	
Suradnik:	Pero Sjekavica, dipl.ing.	travanj, 2016.	Stranica: 1/1	T.D. 98-2/15	Nacrt br: F1