

IZJAVA O SUKLADNOSTI

Broj 13-F0058/2013


Uvoznik:	Produktronika d.o.o., Janka Leskovara 13, Zagreb
Naziv proizvoda:	Adresabilni U/I modul s relejnim izlazom
Tip/model:	CHQ-MRC2(SCI) i CHQ-MRC2(HFP)-SCI
Proizvođač:	Hochiki Euripe Ltd, Grosvenor Road, Gillingham, Kent, UK
Trgovačka Marka:	Hochiki Euripe Ltd, Grosvenor Road, Gillingham, Kent, UK

**Gore navedeni proizvodi sukladan je zahtjevima niže
Navedenih proizvoda (EU direktiva) i harmoniziranih normi:**

Pravilnik/propis:	Pravilnik o elektromagnetskoj kompatibilnosti (NN 112/08).
HRN EN norme:	HREN 54-17:2005 dio 17 HREN 54-18:2005 dio 18
EN norme:	HREN 54-17:2005 part 17 HREN 54-18:2005 part 18
Sukladnost:	EC-Certificate of Conformity No.: 0832-CPR-F0058/13 Uredba EU No: 305/2011

Izjava potpisana u ime uvoznika:

Domagoj Ručević, direktor



PRODUKTRONIKA
d.o.o. ZAGREB

U Zagrebu, 21. listopad 2013.

DECLARATION OF PERFORMANCE

According to Construction Products Regulation EU N° 305/2011

N° 0832 – CPR – F0058/13

Product Name: CHQ-MRC2(SCI) & CHQ-MRC2(HFP)-SCI

Intended use: Intelligent analogue addressable mains relay controller module with short circuit isolator for use in fire detection and alarm systems for buildings.

Manufactured by : Hochiki Europe (UK) Ltd, Grosvenor Road, Gillingham, Kent, ME8 0SA

Authorised representative: N/A

System of Assessment: System 1

Assessed by: BRE Global Limited (Notified Body 0832) has performed type testing of the product, initial inspection of the manufacturing plant and of factory production control with continuous surveillance, assessment and evaluation of factory production control under system 1 and issued following certificate of conformity:

0832 – CPR – F0058

Declared performance: All requirements including all essential characteristics⁽¹⁾ and corresponding performances⁽²⁾ as described in the harmonised standards:
EN54-18:2005 Fire detection and fire alarm systems - Part 18:
Input/output devices
EN54-17:2005 Fire detection and fire alarm systems - Part 17:
Short circuit isolators
for the intended uses indicated above have been determined.
⁽¹⁾See Annex A for the Essential Characteristics details
⁽²⁾See Annex B for additional performance details

The performance of the above mentioned products are in conformity with the performance and essential characteristics declared within this certificate. This declaration of performance is issued under the sole responsibility of Hochiki Europe (UK) Ltd.

Signed for and on behalf of the manufacturer by:

.....
Ray Turner
Compliance Manager

Date of issue 21st October 2013

Page 1 of 2

HOCHIKI EUROPE (UK) LIMITED

Grosvenor Road, Gillingham Business Park,
Gillingham, Kent, ME8 0SA, United Kingdom
Telephone: +44 (0)1634 260133
Facsimile: +44 (0)1634 260132
e-mail (UK Sales): sales@hochikieurope.com
e-mail (Non UK Sales): export@hochikieurope.com
www.hochikieurope.com

Reg. Address: 11 Raven Wharf, Lafone Street,
Butlers Wharf, London SE1 2LR
Registered in England no. 2639909
VAT no. GB 573 8188 03



Annex A - Essential Characteristics

Essential characteristics	EN54-17:2005	EN54-18:2005	Performance
Performance under fire conditions	5.2	5.1.4	Pass
Operational reliability	4	5.1.4	Pass
Durability of operational reliability: Temperature resistance	5.4, 5.5	5.3, 5.4	Pass
Durability of operational reliability: humidity resistance	5.6, 5.7	5.5, 5.6	Pass
Durability of operational reliability: corrosion resistance	5.8	5.7	Pass
Durability of operational reliability; vibration resistance	5.9 to 5.12	5.8 to 5.11	Pass
Durability of operational reliability; electrical stability	5.3, 5.13	5.2, 5.12	Pass

Annex B – Additional Performance Details
Not applicable.

HOCHIKI EUROPE (UK) LIMITED

Grosvenor Road, Gillingham Business Park,
Gillingham, Kent, ME8 0SA, United Kingdom

Telephone: +44 (0)1634 260133

Facsimile: +44 (0)1634 260132

e-mail (UK Sales): sales@hochikieurope.com

e-mail (Non UK Sales): export@hochikieurope.com

www.hochikieurope.com

Reg. Address: 11 Raven Wharf, Lafone Street,
Butlers Wharf, London SE1 2LR

Registered in England no. 2639909

VAT no. GB 573 8188 03

