JGL d.d.
Svilno 20
51000 Rijeka
OIB: 20950636972

Rijeka, 18. listopada 2021.

SVIM ZAINTERSIRANIM GOSPODARSKIM SUBJEKTIMA

Predmet: Odgovor na upit u postupku nabave s obveznom objavom za predmet nabave: Nabava opreme i uređaja za pilot pogon: Grupa 1 - Specijalizirana radna površina za rad s opasnim kemikalijama (digestori) i Grupa 2 – Mješači

Naručitelj je u predmetnom postupku nabave zaprimio upit zainteresiranog gospodarskog subjekta za grupu 1 predmeta nabave sljedećeg sadržaja:

UPIT:

„Vezano za poziv za dostavu ponuda za nabavu opreme i uređaja za pilot, evidencijski broj nabave: EV-35, za grupu 1., molim Vas slijedeću informaciju:

- *Da li za tražene digestore trebate varijabilni protok zraka ili ne?“*

ODGOVOR NARUČITELJA:

U sklopu HVAC sustava imamo zaklopke koje osiguravaju varijabilni protok zraka. Dakle, to ne dolazi s digestorom već od strane HVAC-a.

Ono što digestor treba imati je kontrolu čeone brzine i mjerenje otvorenosti prednjih vrata. Temeljem tih informacija HVAC kontrolira otvorenost zaklopke.

Prethodni odgovor, Naručitelj javno objavljuje na istim internetskim stranicama na kojima je objavljena i osnovna dokumentacija te isti čini sastavni dio natječajne dokumentacije.
Naručitelj poziva sve zainteresirane gospodarske subjekte da pročitaju i prate sva pojašnjenja koja su objavljena u sklopu ovog postupka nabave.

Odbor za nabavu

JGL d.d.
Svilno 20
51000 Rijeka
Identification / Registration Number: 20950636972

Rijeka, October 18th 2021.

TO ALL INTERESTED BUSINESS ENTITIES

Subject: *Response to the request in the procurement procedure with mandatory publication for the subject of procurement: Procurement of equipment and devices for pilot plant. Lot 1 - Specialized work surface for working with hazardous chemicals (fume hoods) and Lot 2 - Mixers*

Contracting authority received a request from an interested economic entity in the subject procurement procedure for Lot 1 with the following content:

REQUEST:

"Regarding the Tender Submission invitation for the procurement of pilot equipment and devices, procurement number: EV-35, for Lot 1, please follow the information:

- *Do you need variable airflow for the required digesters or not?"*

THE CONTRACTING AUTHORITY'S RESPONSE:

Within the HVAC system we have flaps that ensure variable airflow. So it doesn't come with a digester but by HVAC.

What the digester must have is the control of the frontal speed and the measurement of the openness of the front door. Based on this information, HVAC controls the openness of the flap.

The previous response, the Contracting Authority publishes on the same website where the basic documentation was published and it is an integral part of the tender documentation.
The contracting authority invites all interested economic operators to read and follow all the explanations published as part of this procurement procedure.

Procurement Committee